

Certificate

Registration No.: PV 50193716

Page 1

Report No.: 15040306.001

License Holder:

Tianwei New Energy (Chengdu) PV Module Co., Ltd.

No.1 Tianwei Road, Southwest Airport Economic Development Zone, Chengdu, Sichuan 610200, P.R. China

Product:

PV Module

Type:

TWxxxP72-EA2 (xxx=260-295, in increment of 5)
TWxxxP60-FA2 (xxx=210-245, in increment of 5)
TWxxxP54-GA2 (xxx=190-220, in increment of 5)
TWxxxP48-HA2 (xxx=170-190, in increment of 5)

Manufacturing Plant:

Tianwei New Energy (Chengdu) PV Module Co., Ltd.

No.1 Tianwei Road, Southwest Airport Economic Development Zone, Chengdu, Sichuan 610200, P.R. China

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 16023583.001

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 7 December 2015.

Certification body

Dipl.-Ing. Bernd Scheirer



Shanghai, 8 December 2010

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
Contact: + (+49) 221 806-1371 email: cert-validity@de.tuv.com